

CERTIFICATE

No. U6 105434 0343 Rev. 00

Holder of Certificate: **LEDVANCE Operation & Management (Shenzhen) Co., Ltd.**

4th Floor of the second building of Liuxian Cultural Park
plant 2, Xinwei Community, Xili Street
Nanshan District
518000 Shenzhen
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Luminaires for emergency lighting (Fixed emergency luminaires)**

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. It is not permitted to alter the certification mark in any way. In addition, the certificate holder must not transfer the certificate to third parties. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64142225018701

Date, 2023-02-28



(Taylor Yao)

CERTIFICATE

No. U6 105434 0343 Rev. 00

Model(s): LN SF 600 P 18W 840 WT IP44 EM;
LN SF 600 P 18W 830 WT IP44 EM;
LN SF 1200 P 32W 840 WT IP44 EM;
LN SF 1200 P 32W 830 WT IP44 EM;
LN SF 1500 P 45W 840 WT IP44 EM;
LN SF 1500 P 45W 830 WT IP44 EM

Brand Name: LEDVANCE



Parameters:

Rated Voltage: 220-240VAC
Rated Frequency: 50/60Hz
Rated Power: See below table for details
Protection Class: I
Degree of Protection: IP44
Blue Light Risk Group: RG0
ta: 40°C

Model No.	Rated Power (W)
LN SF 600 P 18W 840 WT IP44 EM	18
LN SF 600 P 18W 830 WT IP44 EM	18
LN SF 1200 P 32W 840 WT IP44 EM	32
LN SF 1200 P 32W 830 WT IP44 EM	32
LN SF 1500 P 45W 840 WT IP44 EM	45
LN SF 1500 P 45W 830 WT IP44 EM	45

Tested according to: EN 60598-2-22:2014/A1:2020
EN IEC 60598-2-1:2021
EN IEC 60598-1:2021/A11:2022

Production Facility(ies): 089721, 101065